



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	8140-2359:0001
<b>CATEGORY:</b>	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
<b>LISTEE:</b>	Anenda Systems Inc. 1278 Cliveden Avenue, Delta, BC V3M 6G4 Contact: Meier, Daniel 16047865847 Email: daniel.meier@al13.com
<b>DESIGN:</b>	Model AL13 Aluminum Plank System. Product is an extruded aluminum cladding that is secured to the wall using an AL13 fastener appropriate for the substrate.  Refer to the manufacturer's installation instructions and product data sheets.
<b>RATING:</b>	Noncombustible  Tested in accordance with ASTM E136
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and SFM label.
<b>APPROVAL:</b>	Listed as exterior aluminum cladding for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details. Model complies with the applicable requirements in ASTM E136-16.
<b>NOTES:</b>	

9-21-22 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/21/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division